



DLA PAT Services
80 Willows Road, Birmingham, B12 9QD



**REGISTER
OF
PORTABLE APPLIANCE TESTS**

On behalf of:

The Burdock Band
80 Willows Road
Birmingham
B12 9QD

Site Tested:

Not applicable

Date of tests:

3 May 2017
(updated 07/12/17)



Test Certificate

Tests Conducted By: DLA PAT Services
80 Willows Road, Birmingham, B12 9QD

On Behalf Of: The Burdock Band

Site: N/A

Location: N/A

Asset id: BUR0906 - BUR0918

No of Tests: 13 **No of Passes:** 13

No. pages in Report: 3

Standard: Testing complies with the Code of Practice for In-Service Inspection and Testing of Electrical Equipment (3rd Ed) © The Institution of Engineering & Technology

Date of Tests: 3 May 2017 - updated 07/12/17

Test Instrument: Primetest 100 A02-0782

Tested By: D Longley

Results: (see following page)

Updates: 07/12/17: Soundcraft Signature replaced with new model; Soundcraft Notepad-12FX purchased in Nov 2017.

Equipment Formal Visual and Combined Inspection & Test Record - Burdock Ceilidh Band													
Ownership	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band	Burdock Band
Appliance ID	BUR0906	BUR0907	BUR0908	BUR0910	BUR0911	BUR0912	BUR0913	BUR0914	BUR0915	BUR0916	BUR0917	BUR0918	BUR0919
Description	4-way lead	Powered speakers	Powered speakers	Active Speaker	Active Speaker	Radio Mic System	5m Cassette Reel	5m Cassette Reel	4-way lead	6-way lead	Mixing Desk	Personal monitor	Mini mixing Desk
Construction Class	Cord	II	II	II	II	II	Cord	Cord	Cord	Cord	I	II	II
Equipment type: S, IT, M, P, H	P	P	P	P	P	P	P	P	P	P	P	P	P
Location	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Particular requirements of location	None	None	None	None	None	None	None	None	None	None	None	None	None
Frequency of formal Visual inspection	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months
Freq. Of combined inspection and testing	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months	12 months
Make	NTA 680	Yamaha Monitor Speaker	Yamaha Monitor Speaker	RCF Evox 5 Active 2-way	RCF Evox 5 Active 2-way	Shure GLXD System WISM35	Masterplug 910-9153	Masterplug 910-9153	Livia 9423	Philex CA-U608A1	Soundcraft 5049556	VoiceSolo FX150	Soundcraft
Model	-	MS101	MS101	MS101	MS101	3012888178-01 AC Adaptor: Shure PS42UK S/n 2915B	910-9153	910-9153	9988N	CA-U608A1	5049556	FY4251500	Notepad-12FX
Serial No	-	QX01120	QX01091	OGTU00057	OHTQ00304	Shure PS42UK S/n 2915B	15W23 33	15W23 34	-	-	615470MU replaced by 6172200Z	-	K178N1200649
Voltage (V)	240V	240V	240V	230V	230V	110/240V	240W	240W	240V	240V	240V	230V	DC 18V
Appliance Rating Current (A) or Watts (W)	13A	30W	30W	450W	450W	9W	2400W unground	2400W unground	13A	13A	30W	80VA	1.3A
Fuse Rating (A)	13A	13A	13A	13A	13A	3A	13A	13A	13A	13A	N/A	13A	N/A
Date of Purchase	Not known	Not known	Not known	07/02/2016	07/02/2016	04/02/2016	13/02/2016	13/02/2016	Not known	Not known	07/12/2017	31/10/2016	10/11/2017
Guarantee	No	No	No	No	No	No	No	No	No	No	Yes	Yes	Yes DV247 Inv SIN-0267494
FORMAL VISUAL INSPECTION HISTORY													
Date	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	03/05/2017	07/12/2017
Environment/Use	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Disconnected	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Visual on Socket-outlet	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Plug and correct fuse	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Flex	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Body/Case	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
TESTING HISTORY													
Earth Continuity	0.16Ω	-	-	0.14Ω	No connection r	-	0.013Ω	0.012Ω	0.14Ω	0.12Ω	0.09Ω	-	-
Pass/Fail	Pass	Pass	Pass	Pass	-	Pass	Pass	Pass	Pass	Pass	Pass	Pass	Pass
Insulation	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ	>19.99MΩ
Pass/Fail	Good	Good	Good	Pass	Pass	Good	Good	Good	Good	Good	Good	Good	Good
Function check	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Earth Leakage (mA) or Touch current (mA)	-	<0.1mA	<0.1mA	0.67mA	0.65mA	<0.1mA	-	-	-	-	0.65mA	0.21mA	-
OK to use YES/NO	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes	Yes
Signature/Initials	DL	DL	DL	DL	DL	DL	DL	DL	DL	DL	DL	DL	DL
Printed name	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley	D Longley